## 6AG1518-4FP00-4AB0

**Data sheet** 



SIPLUS S7-1500 CPU 1518F-4 PN/DP based on 6ES7518-4FP00-0AB0 with conformal coating, 0...+60 °C, central processing unit with work memory 4.5 MB for program and 10 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface, Ethernet, 3rd interface, Ethernet, 4th interface, PROFIBUS, 1 ns bit performance, SIMATIC Memory Card required

General information	
Product type designation	CPU 1518F-4PN/DP
Product function	
● I&M data	Yes; I&M0 to I&M3
• Isochronous mode	Yes; Distributed and central; with minimum OB 6x cycle of 125 $\mu s$ (distributed) and 1 ms (central)
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	see entry ID: 109746275
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	6.1 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	1.55 A
Inrush current, max.	2.4 A; Rated value
l²t	0.02 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	12 W
Power consumption from the backplane bus (balanced)	30 W
Power loss	
Power loss, typ.	24 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
<ul><li>integrated (for program)</li></ul>	9 Mbyte
integrated (for data)	60 Mbyte
Load memory	
<ul> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>	32 Gbyte

Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	1 ns
for word operations, typ.	2 ns
for fixed point arithmetic, typ.	2 ns
for floating point arithmetic, typ.	6 ns
CPU-blocks	0115
Number of elements (total)	20 000: Plocks (OP EP EC DP) and UDTs
DB	20 000; Blocks (OB, FB, FC, DB) and UDTs
Number range	1 60 999; subdivided into: number range that can be used by the user: 1
• Number range	59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	16 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	1 Mbyte
FC	
Number range	0 65 535
• Size, max.	1 Mbyte
ОВ	
• Size, max.	1 Mbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
Number of delay alarm OBs	20
Number of cyclic interrupt OBs	20; with minimum OB 3x cycle of 100 μs
Number of process alarm OBs	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	3
<ul> <li>Number of technology synchronous alarm OBs</li> </ul>	2
Number of startup OBs	100
<ul> <li>Number of asynchronous error OBs</li> </ul>	4
<ul> <li>Number of synchronous error OBs</li> </ul>	2
<ul> <li>Number of diagnostic alarm OBs</li> </ul>	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	768 kbyte; In total; available retentive memory for bit memories, timers,
	counters, DBs, and technology data (axes): 700 KB
Extended retentive data area (incl. timers, counters, flags), max.	20 Mbyte; When using PS 6 0W 24/48/60 V DC HF
Flag	1011.1
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes

Retentivity preset	No
Local data	
per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	16 384; max. number of modules / submodules
I/O address area	
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
— Outputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	- · · · · · · ·
Number of subprocess images, max.	32
Hardware configuration	<u> </u>
Number of distributed IO systems	64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
<ul><li>integrated</li></ul>	1
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be
	inserted in total
Number of IO Controllers	
• integrated	2
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	modica in total
Modules per rack, max.	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	·
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available
	slots
Time of day	
Clock	
<ul> <li>Type</li> </ul>	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
<ul><li>supported</li></ul>	Yes
• to DP, master	Yes
• in AS, master	Yes
• in AS, device	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	3
Number of PROFIBUS interfaces	1
1. Interface	
Interface types	
• RJ 45 (Ethernet)	Yes; X1
<ul><li>Number of ports</li></ul>	2
• integrated switch	Yes
Protocols	
• IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
- 1100 001101	100

Media redundancy	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— Isochronous mode	Yes
Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
Prioritized startup	Yes; Max. 32 PROFINET devices
Number of connectable IO Devices, max.	512; In total, up to 1 000 distributed I/O devices can be connected via AS-i,
	PROFIBUS or PROFINET
<ul> <li>Of which IO devices with IRT, max.</li> </ul>	64
<ul> <li>Number of connectable IO Devices for RT, max.</li> </ul>	512
— of which in line, max.	512
Number of IO Devices that can be simultaneously	8; in total across all interfaces
activated/deactivated, max.	
Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 125 μs	125 µs
— for send cycle of 187.5 μs	187.5 µs
— for send cycle of 250 µs	250 µs to 4 ms
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 $\mu s:375~\mu s,625~\mu s3$ 875 $\mu s)$
Update time for RT	
— for send cycle of 250 $\mu s$	250 µs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes; Minimum send cycle of 250 μs
— PROFlenergy	Yes; per user program
— Shared device	Yes
<ul> <li>Number of IO Controllers with shared device, max.</li> </ul>	4
activation/deactivation of I-devices	Yes; per user program
Asset management record	Yes; per user program
2. Interface	
Interface types	V V0
RJ 45 (Ethernet)	Yes; X2
Number of ports	1
integrated switch	No
Protocols	Vee IDv4
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	No
PROFINET IO Controller	
Services	
<ul> <li>PG/OP communication</li> </ul>	Yes

— Isochronous mode	No 
Direct data exchange	No
— IRT	No
— PROFlenergy	Yes; per user program
<ul><li>— Prioritized startup</li></ul>	No No
<ul> <li>Number of connectable IO Devices, max.</li> </ul>	128; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
<ul> <li>Number of connectable IO Devices for RT, max.</li> </ul>	128
— of which in line, max.	128
<ul> <li>Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
<ul> <li>Number of IO Devices per tool, max.</li> </ul>	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for RT	
— for send cycle of 1 ms	1 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	No
— PROFlenergy	Yes; per user program
Prioritized startup	No
·	
— Shared device	Yes
<ul> <li>Number of IO Controllers with shared device, max.</li> </ul>	4
<ul> <li>activation/deactivation of I-devices</li> </ul>	Yes; per user program
Asset management record	Yes; per user program
3. Interface	
Interface types	
<ul><li>RJ 45 (Ethernet)</li></ul>	Yes; X3
<ul> <li>Number of ports</li> </ul>	1
<ul> <li>integrated switch</li> </ul>	No
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	No
PROFINET IO Device	No
SIMATIC communication	Yes
Open IE communication	Yes
Web server	Yes
4. Interface	
Interface types	
	Voc. VA
RS 485      Number of ports	Yes; X4
Number of ports	1
Protocols	V
PROFIBUS DP master	Yes
PROFIBUS DP device	No
SIMATIC communication	Yes
PROFIBUS DP master	
<ul> <li>Number of connections, max.</li> </ul>	48; for the integrated PROFIBUS DP interface
max. number of DP devices	125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
Services	
— PG/OP communication	Yes
— Equidistance	Yes
— Isochronous mode	Yes
<ul> <li>activation/deactivation of DP devices</li> </ul>	Yes
Interface types	
RJ 45 (Ethernet)	
	Yes
• 100 Mbps	
<ul><li>1000 Mbps</li><li>Autonegotiation</li></ul>	Yes; Only possible at the X3 interface of the CPU 1518 Yes

Autocrossing	Yes
Industrial Ethernet status LED	Yes
RS 485	
Transmission rate, max.	12 Mbit/s
Protocols	
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	
<ul> <li>Number of connections, max.</li> </ul>	384; via integrated interfaces of the CPU and connected CPs / CMs
<ul> <li>Number of connections reserved for ES/HMI/web</li> </ul>	10
<ul> <li>Number of connections via integrated interfaces</li> </ul>	320
Number of S7 routing paths	64; in total, only 16 S7-Routing connections are supported via PROFIBUS
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	only via 1st interface (X1)
— MRP	Yes; as MRP redundancy manager and/or MRP client
<ul> <li>MRP interconnection, supported</li> </ul>	Yes; as ring node according to IEC 62439-2 Edition 2.0
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication	
• S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	V
• TCP/IP	Yes
— Data length, max.	64 kbyte
— several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; 128 multicast circuits (of which max. 5 via X1)
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	Von
Runtime license required     ORC LIA Client	Yes
OPC UA Client  Application authoritisation	Yes
Application authentication	Yes  Available convity policies: Name Posici 29 Posic 256 Posit 5
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
User authentication	"anonymous" or by user name & password
Number of connections, max.	40
Number of nodes of the client interfaces, recommended max.  Number of elements for one call of	5 000
<ul> <li>Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_I max.</li> </ul>	
<ul> <li>Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.</li> </ul>	20
<ul> <li>Number of elements for one call of OPC_UA_MethodGetHandleList, max.</li> </ul>	100
<ul> <li>Number of simultaneous calls of the client instructions for session management, per connection,</li> </ul>	1

max.	
Number of simultaneous calls of the client	5
instructions for data access, per connection, max.	
Number of registerable nodes, max.	5 000
<ul> <li>Number of registerable method calls of OPC_UA_MethodCall, max.</li> </ul>	100
Number of inputs/outputs when calling OPC_UA_MethodCall, max.	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
<ul> <li>Application authentication</li> </ul>	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
<ul><li>User authentication</li></ul>	"anonymous" or by user name & password
— Number of sessions, max.	64
<ul> <li>Number of accessible variables, max.</li> </ul>	200 000
<ul> <li>Number of registerable nodes, max.</li> </ul>	50 000
<ul> <li>Number of subscriptions per session, max.</li> </ul>	20
<ul><li>— Sampling interval, min.</li></ul>	10 ms
— Publishing interval, min.	10 ms
<ul> <li>Number of server methods, max.</li> </ul>	100
<ul> <li>Number of inputs/outputs per server method, max.</li> </ul>	20
<ul> <li>Number of monitored items, recommended max.</li> </ul>	10 000; for 1 s sampling interval and 1 s send interval
<ul> <li>Number of server interfaces, max.</li> </ul>	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
<ul> <li>Number of nodes for user-defined server interfaces,</li> </ul>	30 000
max.	
Alarms and Conditions	400
— Number of program alarms	400
Number of alarms for system diagnostics	200
Further protocols	
MODBUS	Yes; MODBUS TCP
Isochronous mode	
Equidistance	Yes
S7 message functions	
S7 message functions  Number of login stations for message functions, max.	64
S7 message functions  Number of login stations for message functions, max.  Program alarms	64 Yes
S7 message functions  Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block,
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients)
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems  Yes; Up to 16 simultaneously (in total across all ES clients)  No  20
S7 message functions  Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control variable	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control variable  Variables	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000  1 000  480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  — of which status variables, max.	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Status/control  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  Forcing  Forcing  Forcing  Forcing, variables, max.  Number of variables, max.	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables  Number of variables, max.  Diagnostic buffer  present	Yes  10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH  5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe) 200 Yes; without fail-safe
Number of login stations for message functions, max.  Program alarms  Number of configurable program messages, max.  Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  Forcing  Forcing  Forcing  Forcing, variables, max.  Number of variables, max.  Number of variables, max.	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000  4 000 1 000 480  Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20  Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe) 200

Traces	
Number of configurable Traces	8; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
<ul> <li>Connection display LINK TX/RX</li> </ul>	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC
a Number of available Metion Central recourses for	program; selection guide via the TIA Selection Tool
<ul> <li>Number of available Motion Control resources for technology objects</li> </ul>	15 360
Required Motion Control resources	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis	
Number of positioning axes at motion control cycle of 4 ms (typical value)	140
Number of positioning axes at motion control cycle of 8 ms (typical value)	192
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
Performance level according to ISO 13849-1	PLe
SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair time	e of 100 hours)
<ul> <li>Low demand mode: PFDavg in accordance with SIL3</li> </ul>	< 2.00E-05
<ul> <li>High demand/continuous mode: PFH in accordance with SIL3</li> </ul>	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
<ul> <li>horizontal installation, min.</li> </ul>	0 °C
horizontal installation, max.	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
<ul> <li>vertical installation, min.</li> </ul>	0 °C
vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
<ul> <li>Installation altitude above sea level, max.</li> </ul>	5 000 m
Ambient air temperature-barometric pressure-altitude  Relative humidity	Restrictions for installation altitudes > 2 000 m, see entry ID: 109763260
With condensation, tested in accordance with IEC 60068- 2-38, max.	100 %; RH incl. condensation/frost (no commissioning under condensation conditions)
Resistance	
Coolants and lubricants	
Resistant to commercially available coolants and lubricants	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
, ,	

- to biologically active substances according to EN Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); 60721-3-3 Class 3B3 on request - to chemically active substances according to EN Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); — to mechanically active substances according to EN Yes; Class 3S4 incl. sand, dust, \* 60721-3-3 Use on ships/at sea to biologically active substances according to EN Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on 60721-3-6 Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity to chemically active substances according to EN degree 3); 3 60721-3-6 - to mechanically active substances according to EN Yes; Class 6S3 incl. sand, dust; \* 60721-3-6 Usage in industrial process technology Yes; Class 3 (excluding trichlorethylene) Against chemically active substances acc. to EN 60654-4 - Environmental conditions for process, measuring Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level and control systems acc. to ANSI/ISA-71.04 LC3 (salt spray) and level LB3 (oil) Remark Note regarding classification of environmental The supplied plug covers must remain in place over the unused interfaces conditions acc. to EN 60721, EN 60654-4 and during operation! ANSI/ISA-71.04 Conformal coating Yes; Class 2 for high reliability . Coatings for printed circuit board assemblies acc. to EN • Protection against fouling acc. to EN 60664-3 Yes; Type 1 protection • Military testing according to MIL-I-46058C, Amendment 7 Yes; Discoloration of coating possible during service life Qualification and Performance of Electrical Insulating Yes; Conformal coating, Class A Compound for Printed Board Assemblies according to IPC-CC-830A configuration / header configuration / programming / header Programming language - LAD Yes; incl. failsafe — FBD Yes; incl. failsafe - STL Yes - SCI Yes - GRAPH Yes Know-how protection • User program protection/password protection Yes Copy protection Yes Block protection Yes Access protection · Password for display Yes Protection level: Write protection Yes; Specific write protection both for Standard and for Failsafe • Protection level: Read/write protection Yes • Protection level: Write protection for Failsafe Yes • Protection level: Complete protection Yes programming / cycle time monitoring / header • lower limit adjustable minimum cycle time • upper limit adjustable maximum cycle time Dimensions Width 175 mm Height 147 mm Depth 129 mm **Veights** 1 988 g Weight, approx.

last modified:

