## SIEMENS

## Data sheet

## 6ES7212-1HE40-0XB0



SIMATIC S7-1200, CPU 1212C, compact CPU, DC/DC/relay, onboard I/O: 8 DI 24 V DC; 6 DO relay 2 A; 2 AI 0-10 V DC, power supply: DC 20.4-28.8 V DC, program/data memory 100 KB

General information	
Product type designation	CPU 1212C DC/DC/relay
Firmware version	V4.6
Engineering with	
<ul> <li>Programming package</li> </ul>	STEP 7 V18 or higher
Supply voltage	
Rated value (DC)	
• 24 V DC	Yes
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Load voltage L+	
<ul> <li>Rated value (DC)</li> </ul>	24 V
<ul> <li>permissible range, lower limit (DC)</li> </ul>	20.4 V
<ul> <li>permissible range, upper limit (DC)</li> </ul>	28.8 V
Input current	
Current consumption (rated value)	400 mA; CPU only
Current consumption, max.	1 200 mA; CPU with all expansion modules
Inrush current, max.	12 A; at 28.8 V
l²t	0.8 A <sup>2</sup> ·s
Output current	
for backplane bus (5 V DC), max.	1 000 mA; Max. 5 V DC for SM and CM
Encoder supply	
24 V encoder supply	
• 24 V	L+ minus 4 V DC min.
Power loss	
Power loss, typ.	9 W
Memory	
Work memory	
integrated	100 kbyte
Load memory	
<ul> <li>integrated</li> </ul>	2 Mbyte
<ul> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>	with SIMATIC memory card
Backup	
• present	Yes
maintenance-free	Yes
without battery	Yes
CPU processing times	
for bit operations, typ.	0.08 µs; / instruction
for word operations, typ.	1.7 µs; / instruction

for floating point arithmetic, typ.	2.3 µs; / instruction
CPU-blocks	
Number of blocks (total)	DBs, FCs, FBs, counters and timers. The maximum number of addressable blocks ranges from 1 to 65535. There is no restriction, the entire working memory can be used
OB	
Number, max.	Limited only by RAM for code
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	14 kbyte
Flag	
• Size, max.	4 kbyte; Size of bit memory address area
Local data	
<ul> <li>per priority class, max.</li> </ul>	16 kbyte; Priority class 1 (program cycle): 16 KB, priority class 2 to 26: 6 KB
Address area	
Process image	
<ul> <li>Inputs, adjustable</li> </ul>	1 kbyte
Outputs, adjustable	1 kbyte
Hardware configuration	
Number of modules per system, max.	3 comm. modules, 1 signal board, 2 signal modules
Time of day	
Clock	
Hardware clock (real-time)	Yes
Backup time	480 h; Typical
• Deviation per day, max.	±60 s/month at 25 °C
Digital inputs	
Number of digital inputs	8; Integrated
<ul> <li>of which inputs usable for technological functions</li> </ul>	6; HSC (High Speed Counting)
Source/sink input	Yes
Number of simultaneously controllable inputs	
all mounting positions	
— up to 40 °C, max.	8
Input voltage	
Rated value (DC)	24 V
● for signal "0"	5 V DC at 1 mA
• for signal "1"	15 V DC at 2.5 mA
Input delay (for rated value of input voltage)	
for standard inputs	
— parameterizable	$0.2\ \text{ms}, 0.4\ \text{ms}, 0.8\ \text{ms}, 1.6\ \text{ms}, 3.2\ \text{ms}, 6.4\ \text{ms}$ and $12.8\ \text{ms}, \text{selectable}$ in groups of four
— at "0" to "1", min.	0.2 ms
— at "0" to "1", max.	12.8 ms
for interrupt inputs	
— parameterizable	Yes
for technological functions	
— parameterizable	Single phase: 3 @ 100 kHz & 3 @ 30 kHz, differential: 3 @ 80 kHz & 3 @ 30 kHz
Cable length	
• shielded, max.	500 m; 50 m for technological functions
• unshielded, max.	300 m; for technological functions: No
Digital outputs	
Number of digital outputs	6; Relays
Switching capacity of the outputs	
• with resistive load, max.	2 A
• on lamp load, max.	30 W with DC, 200 W with AC
Output delay with resistive load	
• "0" to "1", max.	10 ms; max.
• "1" to "0", max.	10 ms; max.
Relay outputs	
Number of relay outputs	6
Number of operating cycles, max.	mechanically 10 million, at rated load voltage 100 000
Cable length	

a shielded may	500 m
<ul> <li>shielded, max.</li> <li>unshielded, max.</li> </ul>	500 m 150 m
Analog inputs	
Number of analog inputs	2
Input ranges	-
Voltage	Yes
Input ranges (rated values), voltages	100
• 0 to +10 V	Yes
— Input resistance (0 to 10 V)	≥100k ohms
Cable length	
• shielded, max.	100 m; twisted and shielded
Analog outputs	
Number of analog outputs	0
Analog value generation for the inputs	
Integration and conversion time/resolution per channel	
<ul> <li>Resolution with overrange (bit including sign), max.</li> </ul>	10 bit
<ul> <li>Integration time, parameterizable</li> </ul>	Yes
Conversion time (per channel)	625 µs
Encoder	
Connectable encoders	
• 2-wire sensor	Yes
1. Interface	
Interface type	PROFINET
Isolated	Yes
automatic detection of transmission rate	Yes
Autonegotiation	Yes
Autocrossing	Yes
Interface types	
• RJ 45 (Ethernet)	Yes
Number of ports	1
integrated switch	No
Protocols	
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server     Media redundancy	Yes
Media redundancy     PROFINET IO Controller	No
Transmission rate, max.	100 Mbit/s
• manshirston rate, max. Services	
— PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
— Isochronous mode	No
— IRT	No
— PROFlenergy	No
- Prioritized startup	Yes
— Number of IO devices with prioritized startup, max.	16
— Number of connectable IO Devices, max.	16
— Number of connectable IO Devices for RT, max.	16
— of which in line, max.	16
- Activation/deactivation of IO Devices	Yes
<ul> <li>— Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8
— Updating time	The minimum value of the update time also depends on the communication component set for PROFINET IO, on the number of IO devices and the quantity of configured user data.
PROFINET IO Device	
Services	
— PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
— Isochronous mode	No
— IRT	No

<b>PPOElonorm</b>	Yes
— PROFlenergy — Shared device	
	Yes
— Number of IO Controllers with shared device, max.  Protocols	2
	No.
Supports protocol for PROFINET IO	Yes
PROFIsafe	No
PROFIBUS	Yes; CM 1243-5 (master) or CM 1242-5 (slave) required
OPC UA	Yes; OPC UA Server
AS-Interface	Yes; CM 1243-2 required
Protocols (Ethernet)	
• TCP/IP	Yes
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Redundancy mode	
Media redundancy	
— MRP	No
— MRPD	No
SIMATIC communication	
S7 routing	Yes
Open IE communication	
• TCP/IP	Yes
— Data length, max.	8 kbyte
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	8 kbyte
• UDP	Yes
— Data length, max.	1 472 byte
Web server	
• supported	Yes
User-defined websites	Yes
OPC UA	
Runtime license required	Yes; "Basic" license required
OPC LIA Server	Yes: data access (read, write, subscribe), method call, runtime license required
OPC UA Server     — Application authentication	Yes; data access (read, write, subscribe), method call, runtime license required Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
<ul> <li>— Application authentication</li> <li>— User authentication</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces,</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> Communication functions / header	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> Communication functions / header S7 communication	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> Communication functions / header <ul> <li>S7 communication</li> <li>supported</li> <li>as server</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> S7 communication <ul> <li>supported</li> <li>as server</li> <li>as client</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 200 1 000 2 2 000 Yes Yes Yes
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> S7 communication <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> Communication functions / header S7 communication <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes Yes See online help (S7 communication, user data size)
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> S7 communication <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 200 1 000 2 2 000 Yes Yes Yes
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> Communication functions / header S7 communication <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes See online help (S7 communication, user data size) PG Connections: 4 reserved / 4 max; HMI Connections: 12 reserved / 18 max; S7 Connections: 8 reserved / 14 max; Open User Connections: 8 reserved / 14 max; Web Connections: 2 reserved / 30 max; OPC UA Connections: 0 reserved
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> S7 communication <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul> Number of connections <ul> <li>overall</li> </ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes See online help (S7 communication, user data size) PG Connections: 4 reserved / 4 max; HMI Connections: 12 reserved / 18 max; S7 Connections: 8 reserved / 14 max; Open User Connections: 8 reserved / 14 max; Web Connections: 2 reserved / 30 max; OPC UA Connections: 0 reserved
<ul> <li>Application authentication</li> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> Sommunication functions / header S7 communication <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul> Test commissioning functions	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes See online help (S7 communication, user data size) PG Connections: 4 reserved / 4 max; HMI Connections: 12 reserved / 18 max; S7 Connections: 8 reserved / 14 max; Open User Connections: 8 reserved / 14 max; Web Connections: 2 reserved / 30 max; OPC UA Connections: 0 reserved

Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Forcing	
• Forcing	Yes
Diagnostic buffer	
• present	Yes
Traces	
<ul> <li>Number of configurable Traces</li> </ul>	2
Memory size per trace, max.	512 kbyte
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
Integrated Functions	
Counter	
Number of counters	6
<ul> <li>Counting frequency, max.</li> </ul>	100 kHz
Frequency measurement	Yes
controlled positioning	Yes
Number of position-controlled positioning axes, max.	8
Number of positioning axes via pulse-direction interface	Up to 4 with SB 1222
PID controller	Yes
Number of alarm inputs	4
Potential separation	
Potential separation digital inputs	
Potential separation digital inputs	500V AC for 1 minute
<ul> <li>between the channels, in groups of</li> </ul>	1
Potential separation digital outputs	
<ul> <li>Potential separation digital outputs</li> </ul>	Relays
<ul> <li>between the channels</li> </ul>	No
<ul><li>between the channels</li><li>between the channels, in groups of</li></ul>	No 2
• between the channels, in groups of	
between the channels, in groups of     EMC     Interference immunity against discharge of static electricity     Interference immunity against discharge of static	
between the channels, in groups of     EMC     Interference immunity against discharge of static electricity	2
between the channels, in groups of     EMC     Interference immunity against discharge of static electricity     Interference immunity against discharge of static	2
between the channels, in groups of      EMC      Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul>	2 Yes
between the channels, in groups of      EMC      Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li></ul>	2 Yes 8 kV
between the channels, in groups of      EMC      Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul>	2 Yes 8 kV
between the channels, in groups of      EMC      Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> <li>Interference immunity to cable-borne interference         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li>	2 Yes 8 kV 6 kV
between the channels, in groups of      EMC      Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> <li>Interference immunity to cable-borne interference         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li>	2 Yes 8 kV 6 kV Yes
between the channels, in groups of      EMC      Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> <li>Interference immunity to cable-borne interference         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li>	2 Yes 8 kV 6 kV Yes Yes
between the channels, in groups of      EMC      Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> <li>Interference immunity to cable-borne interference         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li>	2 Yes 8 kV 6 kV Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> </ul>	2 Yes 8 kV 6 kV Yes Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against conducted variable disturbance indute on the statement of the statement o</li></ul>	2 Yes 8 kV 6 kV Yes Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against conducted variable disturbance indu <ul> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes ced by high-frequency fields
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes ced by high-frequency fields Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-5</li> </ul> </li> <li>Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> </ul> </li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes ceed by high-frequency fields Yes Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes ced by high-frequency fields Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-5</li> </ul> </li> <li>Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> </ul> </li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes ced by high-frequency fields Yes Yes; Group 1 Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> <li>Emission of radio interference acc. to EN 55 011</li> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes ced by high-frequency fields Yes Yes; Group 1 Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbance indute</li> <li>Interference immunity against conducted variable disturbance indute</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> <li>Emission of radio interference acc. to EN 55 011</li> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul>	2 Yes 8 KV 6 KV Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> <li>Emission of radio interference acc. to EN 55 011</li> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> <li>Degree and class of protection</li> <li>IP degree of protection</li>	2 Yes 8 KV 6 KV Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against conducted variable disturbance indu <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> <li>Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> </li> <li>Degree and class of protection</li> <li>IP degree of protection</li> </ul>	2 Yes 8 KV 6 KV Yes
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity against voltage surge <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against conducted variable disturbance indu <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> <li>Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> </li> <li>Degree and class of protection <ul> <li>IP degree of protection</li> </ul> </li> <li>Standards, approvals, certificates</li> <li>CE mark</li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes Ced by high-frequency fields Yes Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits for Class B according to EN 55011
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against conducted variable disturbance indu <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> <li>Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> </li> <li>Degree and class of protection <ul> <li>IP degree of protection</li> </ul> </li> <li>Standards, approvals, certificates</li> <li>CE mark</li> <li>UL approval</li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes Yes Ced by high-frequency fields Yes Yes; Group 1 Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits for Class B according to EN 55011
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> Degree and class of protection IP degree of protection Standards, approvals, certificates CE mark <ul> <li>UL approval</li> <li>cULus</li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes Yes Yes Yes Yes Yes Yes; Group 1 Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits for Class B according to EN 55011
<ul> <li>between the channels, in groups of</li> <li>EMC</li> <li>Interference immunity against discharge of static electricity <ul> <li>Interference immunity against discharge of static electricity acc. to IEC 61000-4-2</li> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> </li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against conducted variable disturbance indu <ul> <li>Interference immunity against conducted variable disturbance indu</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> <li>Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> </li> <li>Degree and class of protection <ul> <li>IP degree of protection</li> </ul> </li> <li>Standards, approvals, certificates</li> <li>CE mark</li> <li>UL approval</li> <li>cULus</li> <li>FM approval</li> </ul>	2 Yes 8 kV 6 kV Yes Yes Yes Ced by high-frequency fields Yes Yes Yes Yes I P20 I P20

Ambient conditions	
Free fall	
Fall height, max.	0.3 m; five times, in product package
Ambient temperature during operation	o.o m, ive times, in product puckage
min.	-20 °C
• max.	60 °C; Number of simultaneously activated inputs or outputs 4 or 3 (no adjacent
• mux.	points) at 60 °C horizontal or 50 °C vertical, 8 or 6 at 55 °C horizontal or 45 °C vertical
<ul> <li>horizontal installation, min.</li> </ul>	-20 °C
<ul> <li>horizontal installation, max.</li> </ul>	0° C
<ul> <li>vertical installation, min.</li> </ul>	-20 °C
<ul> <li>vertical installation, max.</li> </ul>	50 °C
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Air pressure acc. to IEC 60068-2-13	
<ul> <li>Operation, min.</li> </ul>	795 hPa
Operation, max.	1 080 hPa
Storage/transport, min.	660 hPa
<ul> <li>Storage/transport, max.</li> </ul>	1 080 hPa
Altitude during operation relating to sea level	
<ul> <li>Installation altitude, min.</li> </ul>	-1 000 m
<ul> <li>Installation altitude, max.</li> </ul>	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
Relative humidity	
Operation, max.	95 %; no condensation
Vibrations	
<ul> <li>Vibration resistance during operation acc. to IEC 60068- 2-6</li> </ul>	2 g (m/s <sup>2</sup> ) wall mounting, 1 g (m/s <sup>2</sup> ) DIN rail
<ul> <li>Operation, tested according to IEC 60068-2-6</li> </ul>	Yes
Shock testing	
• tested according to IEC 60068-2-27	Yes; IEC 68, Part 2-27 half-sine: strength of the shock 15 g (peak value), duration 11 ms
Pollutant concentrations	
<ul> <li>SO2 at RH &lt; 60% without condensation</li> </ul>	S02: < 0.5 ppm; H2S: < 0.1 ppm; RH < 60% condensation-free
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes
— FBD	Yes
— SCL	Yes
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
Copy protection	Yes
Block protection	Yes
Access protection	
<ul> <li>protection of confidential configuration data</li> </ul>	Yes
<ul> <li>Protection level: Write protection</li> </ul>	Yes
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes
<ul> <li>Protection level: Complete protection</li> </ul>	Yes
programming / cycle time monitoring / header	
adjustable	Yes
Dimensions	
	90 mm
Width	
Width Height	100 mm
	100 mm 75 mm
Height	

last modified: